

W.O. 21210

**APPLICATION FOR OCCUPANCY**  
**RIGHT-OF-WAY OF COUNTY HIGHWAYS**

To: The Board of County Commissioners Brookings County, South Dakota.

Application is made by Sioux valley energy for occupancy of Right-of-Way

**ADDRESS OF PROPOSED CONSTRUCTION**

City/Towship Name: Parnell, Section: 36 Quarter Section: NE (NW) SE SW

Street/Avenue of Construction: 483 ave, Nearest Intersection: 2195+

Distance from nearest intersection: 34 ft North (South) East West

A sketch showing the location must be attached.

The following information is pertinent to the proposed installation:

1. Intended usage 7.2 KV Distribution
2. Cable Type 4/0 ACSR Conductor
3. Outside Diameter or Pipe Size
4. Method of Installation Digger Derrick, Aerial Lift
5. Crossing Bituminous Roads NO County Gravel

\*This installation will comply with the National Safety Code and all Federal Guidelines.

\*Warning signs will be installed where appropriate.

\*Ditches will be restored back to present condition.

\*Owner will move its buried cable or pipe, in case of road construction, at no cost to the County.

\*Prior to any road construction or maintenance within the County, the owner shall call South Dakota One-Call at 1-800-781-7474 for location of the facilities.

Signature of Applicant: Steve L Gwyrystn Date: 1-27-2016

Applicant Address: P.O. Box 216 Colman S.D. 57017

Phone: 1-800-234-1960 Fax: 1-800-234-1690

Signature of Adjacent Landowner: \_\_\_\_\_ Date: \_\_\_\_\_  
(Owns property immediately adjacent to the public right-of-way that is affected by the Applicant's proposed installation)

Adjacent Landowner Address: \_\_\_\_\_

Phone: \_\_\_\_\_ Fax: \_\_\_\_\_

Recommended for Approval:

By: Richard Bud Date: 1-27-2016  
(Brookings County Superintendent)

Approved: Board of County Commissioners

By: WA Date: 1-27-2016  
(Commission Chairman)



7-3-26

483 AVE

082839

082838

7-3-25

106

105

104

219 ST

103

102

101

100

ACSR-410-200

027108

099201

099202

ACSR-410520

109N  
48W  
Sect. 35

109N  
48W  
Sect. 35

new 3 phase overhead crossing  
replacing existing 1 phase  
crossing will have 24 ft of  
clearance from center of  
road

7-3-36

7-3-35

Lynn  
Lynn  
excluding  
35